

Certificate of Compliance

Certificate: 2028018

Master Contract: 243143

Project: 2028018

Date Issued: April 10, 2008

Issued to: RST Rabe-System-Technik & Vertriebs GmbH
Otto-Lilienthal-Strasse 19
Wallenhorts, 49134
GERMANY
Attention: Mr. Oliver Kalmey

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Lina Bartolotta

Authorized by: Calvin McKenzie
Product Group Manager

PRODUCTS

CLASS 4412 01 OUTLET BOXES AND FITTINGS Bushings, Fittings
CLASS 4412 81 OUTLET BOXES AND FITTINGS Bushings, Fittings - Certified to U.S. Standards

- Non-metallic, cord connectors, Cat Nos 12080512 (M12), 12080516 (M16), 12480516 (M16), 12080520 (M20), 12480520 (M20), 12080522 (M20), 12480522 (M20), 12080525 (M25), 12480525 (M25), 12080532 (M32), 12080540 (M40), 12080550 (M50), 12080563 (M63), 12180512 (M12), 12180516 (M16), 12184516 (M16), 12180520 (M20), 12184520 (M20), 12180522 (M20), 12184522 (M20), 12180525 (M25), 12184525 (M25), 12180532 (M32), 12180540 (M40), 12180550 (M50), 12180563 (M63), 12080038 (NPT3/8), 12080012 (NPT1/2), 12085012 (NPT1/2), 12085034 (NPT3/4), 12080100 (NPT1), 12080407 (PG7), 12080409 (PG9), 12080411 (PG11), 12080413 (PG13,5), 12080416 (PG16), 12080421 (PG21), 12080429 (PG29), 12080436 (PG36), 12080442 (PG42), 12080448 (PG48), 12380038 (NPT3/8), 12385038 (NPT3/8), 12380012 (NPT1/2), 12385012 (NPT1/2), 12385112 (NPT1/2), 12380034 (NPT3/4), 12385034 (NPT3/4), 12385134 (NPT3/4), 12385234 (NPT3/4), for use in dry indoor locations only.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.

Certificate: 2028018

Project: 2028018



Master Contract: 243143

Date Issued: April 10, 2008

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 18.3-04 - Conduit, Tubing, and Cable Fittings
ANSI/UL Standard 514B - Fittings For Conduit and Outlet Boxes

MARKINGS

The CSA Mark, the company name or tradename/trademark or file number 243143, model designation, and any "Cautions" or other information as specified in the Certification Report.



Supplement to Certificate of Compliance

Certificate: 2028018

Master Contract: 243143

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
		<u>Submittor – Bimed Teknik Aletler Sanayi Ve Ticaret A.S. (MC 190896)</u>
		<u>Listee – RST Rabe-System-Technik & Vertriebs GmbH (MC 243143)</u>
2028018 (LR 115116)	April 10/08	BM-0S 12080512 BM-01 12080516 BM-01L 12480516 BM-02 12080520 BM-02L 12480520 BM-03 12080522 BM-04 12480522 BM-05 12080525 BM-06 12480525 BM-07 12080532 BM-08 12080540 BM-09 12080550 BM-10 12080563 BI-0S 12180512 BI-01 12180516 BI-01L 12184516 BI-02 12180520 BI-02L 12184520 BI-03 12180522 BI-04 12184522 BI-05 12180525 BI-06 12184525 BI-07 12180532 BI-08 12180540 BI-09 12180550 BI-10 12180563 BSPA-01 12080038 BSPB-02 12080012 BSPC-02 12085012 BSPD-03 12085034 BSP-04 12080100

Supplement to Certificate of Compliance

Cont'd

		<u>Submittor – Bimed Teknik Aletler Sanayi Ve Ticaret A.S. (MC 190896)</u>	<u>Listee – RST Rabe-System-Technik & Vertriebs GmbH (MC 243143)</u>
2028018 (LR 115116)	April 10/08	BS-01	12080407
		BS-02	12080409
		BS-03	12080411
		BS-04	12080413
		BS-05	12080416
		BS-06	12080421
		BS-07	12080429
		BS-08	12080436
		BS-09	12080442
		BS-10	12080448
		BNSPA-01	12380038
		BNSPA-21	12385038
		BNSPB-02	12380012
		BNSPC-02	12385012
		BNSPC-22	12385112
		BNSPC-03	12380034
		BNSPD-23	12385034
		BNSPD-03	12385134
		BNSPD-23	12385234