



中国国家强制性产品认证证书

证书编号: 2020322313001350

认证委托人名称及地址

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

生产者名称及地址

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

生产企业名称及地址

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

产品名称和系列、型号、规格
管接头
AB,AJ

产品标准和技术要求

GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

上述产品符合《强制性产品认证实施规则 防爆电气》
(CNCA-C23-01:2024)的要求, 特发此证。

发证日期:2025 年 09 月 08 日 有效期至:2030 年 09 月 07 日

首次发证日期:2020 年 09 月 15 日

认证模式:型式试验+初始工厂检查+获证后监督

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



批 准:

上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2020322313001350

NAME AND ADDRESS OF THE APPLICANT

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

NAME AND ADDRESS OF THE MANUFACTURER

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

NAME AND ADDRESS OF THE FACTORY

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

NAME, SERIES, MODEL AND SPECIFICATION

Gland adaptor
AB,AJ

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

This is to certify that the above-mentioned product(s) complies with the requirements of
implementation rules for compulsory certification (CNCA-C23-01:2024).

Issue date:2025-09-08 Valid until:2030-09-07

Date of initial issue:2020-09-15

Type of Certification: Type test + Initial inspection + Surveillance inspection

The certificate details and validity can be verified by scanning the QR code below or logging into the
issuing authority's official website. It can also be inquired on the CNCA website (www.cnca.gov.cn).

(In case of dispute, the Chinese text shall prevail.)



SITIILAS
Worldwide Access

APPROVAL:

Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书

证书编号: 2020322313001350

证书附页: 第 1 页 共 1 页

产品名称:

管接头

型号规格:

AB、AJ

防爆标志:

Ex db II C Gb、Ex eb II C Gb、Ex tb IIIC Db

电气参数:

/

相关报告编号:

2023S17402-011546

使用条件:

1. 特殊(限制)使用条件:

当产品材质为铝合金时, 采用 4J 低能量进行冲击试验, 使用时须避免危险能量的冲击。

2. 其他相关信息:

1) 使用工作温度: $-60^{\circ}\text{C}\sim+200^{\circ}\text{C}$ 。

2) 产品外壳防护等级为 IP6X。

本页为证书附页, 应与证书主页同时使用。



SITIAS
Worldwide Access

批准:

上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书

证书编号: 2020322313001351

认证委托人名称及地址

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

生产者名称及地址

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

生产企业名称及地址

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

产品名称和系列、型号、规格

变径管接头

BB,BJ

产品标准和技术要求

GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

上述产品符合《强制性产品认证实施规则 防爆电气》

(CNCA-C23-01:2024)的要求, 特发此证。

发证日期:2025 年 09 月 05 日 有效期至:2030 年 09 月 04 日

首次发证日期:2020 年 09 月 15 日

认证模式:型式试验+初始工厂检查+获证后监督

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



批 准:

上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2020322313001351

NAME AND ADDRESS OF THE APPLICANT

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

NAME AND ADDRESS OF THE MANUFACTURER

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

NAME AND ADDRESS OF THE FACTORY

EATON ELECTRICAL SYSTEMS Ltd
Westgate Aldridge West Midlands WS9 8FS UK

NAME, SERIES, MODEL AND SPECIFICATION

Gland reducer
BB,BJ

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

This is to certify that the above-mentioned product(s) complies with the requirements of
implementation rules for compulsory certification (CNCA-C23-01:2024).

Issue date:2025-09-05 Valid until:2030-09-04

Date of initial issue:2020-09-15

Type of Certification: Type test + Initial inspection + Surveillance inspection

The certificate details and validity can be verified by scanning the QR code below or logging into the
issuing authority's official website. It can also be inquired on the CNCA website (www.cnca.gov.cn).

(In case of dispute, the Chinese text shall prevail.)



SITIAS
Worldwide Access

APPROVAL:

Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书

证书编号: 2020322313001351

证书附页: 第 1 页 共 1 页

产品名称:

变径管接头

型号规格:

BB、BJ

防爆标志:

Ex db II C Gb , Ex eb II C Gb , Ex tb IIIC Db

电气参数:

/

相关报告编号:

2023S17402-011547

使用条件:

1. 特殊(限制)使用条件: 当产品材质为铝合金时, 采用 4J 低能量进行冲击试验, 使用时须避免危险能量的冲击。
2. 其他相关信息:
 - 1) 使用工作温度: $-60^{\circ}\text{C}\sim+200^{\circ}\text{C}$ 。
 - 2) 产品外壳防护等级为 IP6X。

本页为证书附页, 应与证书主页同时使用。



SITIAS
Worldwide Access

批准:

上海仪器仪表自控系统检验测试所有限公司